


STATE 1973-1974-20.65

Send original copy by certified mail to the Texas Water Development Board, P. O. Box 13087, Austin, Texas 78711. State of Texas 31° 39' 14" 97° 27' 14" 699' For TWDB use only Well No. 40-21-8A Located on map Yes Received: 7/3/73

1) OWNER: Person having well drilled PAUL BRUNE (Name) Address VALLEY MILLS (Street or RFD) TEX. (City) (State) Landowner SAME (Name) Address (Street or RFD) (City) (State)

2) LOCATION OF WELL: County MCLENNAN, 1 1/2 miles in SE direction from VALLEY MILLS (Town) (N.E., S.W., etc.)



Give legal location with distances and directions from adjacent sections or survey lines. Labor League Block Survey Abstract No. (NW 1/4 NE 1/4 SW 1/4 SE 1/4) of Section

3) TYPE OF WORK (check): New Well [checked] Deepening Reconditioning Plugging 4) PROPOSED USE (check): Domestic [checked] Industrial Municipal Irrigation Test Well Other 5) TYPE OF WELL (check): Rotary [checked] Driven Dug Cable Jetted Bored

6) WELL LOG: Diameter of hole 7 1/8 + 7 3/8 in. Depth drilled 1100 ft. Depth of completed well 100 ft. Date drilled 8/16/73 All measurements made from 3 ft. above ground level.

Table with 3 columns: From (ft.), To (ft.), Description and color of formation material. Rows include: 0-15 ROCK, 16-39 BLUE ROCK, 40-184 LIME, 180-356 BLUE SH., 357-364 PALM SPRING SAND, 365-859 BLUE ROSE, 860-890 1ST TRINITY, 891-999 RED SAND, 1000-1095 2ND TRINITY, 1096-1100 YELLOW SAND & GRAVEL.

9) Casing: Type: Old [checked] New [checked] Steel [checked] Plastic Other Cemented from ft. to ft. Diameter (inches) Setting From (ft.) To (ft.) Gage 7" OD 0 700 5 1/2" OD 701 1100 10 5/8" 0 21' 10) SCREEN: Type Perforated [checked] Slotted Diameter (inches) Setting From (ft.) To (ft.) Slot Size 5 1/2" OD 1000 1100

7) COMPLETION (check): Straight wall [checked] Gravel packed Other 200 SCS. CEMENT Under reamed Open Hole

11) WELL TESTS: Was a pump test made? Yes No If yes, by whom? Yield: 20 gpm with ft. drawdown after hrs. Bailer test 20 gpm with 30 ft. drawdown after 1 hrs. Artesian flow gpm 300' DRAWDOWN Temperature of water

8) WATER LEVEL: Static level 270 ft. below land surface. Date 8/16/73 Artesian pressure lbs. per square inch Date Depth to pump bowls, cylinder, jet, etc., ft. below land surface.

12) WATER QUALITY: Was a chemical analysis made? Yes No Did any strata contain undesirable water? Yes No Type of water? depth of strata

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief.

NAME RAY MEADOWS (Type or Print) Water Well Drillers Registration No. ADDRESS 3405 MAC ARTHUR (Street or RFD) WACO (City) TEX. (State) (Signed) [Signature] (Water Well Driller) RAY MEADOWS & SONS (Company Name)

Please attach electric log, chemical analysis, and other pertinent information, if available.

Additional instructions on reverse side.

40-21-801